



FIRST FLOOR PLAN

Existing circuitry to remain.  
Replacement of fittings to be determined by the contractor on site.

Ceiling Void:  
U/S Roof deck - 870  
U/S Purlin - 680

- This is not an installation drawing.
- The final coordination of services, specialist Sub-Contractors, and building structure is the responsibility of the building services Contractor.
- Do not scale from this drawing.
- This drawing shall be read in conjunction with the MEP Specification.
- The installation of services shall be in compliance with the workmanship clauses detailed in the Specification.

Notes

Legend

- Thom Beta 3 Recessed 600x600mm LED Luminaire 30W, 4000K, E-Devices 3Hour Battery Back Up.
- Thom Resilive Surface Mounted 600mmØ LED Luminaire 25W, 3000K, 4000K, E-Devices 3Hour Battery Back Up.
- PIR Movement Sensor complete with daylight sensing.
- Thom Voyager Sigma LED Emergency Fitting.

Safety, Health & Environmental Information

In addition to the hazards / risks normally associated with the types of work detailed on this drawing, note the following:

- Construction  
1. None identified at date of issue.
- Maintenance / Cleaning  
1. None identified at date of issue.
- Decommissioning / Demolition  
1. None identified at date of issue.
- It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved method statement.

Issued For Information - Updates	RS	Dec 23	P02
Issued For Information	RS	Nov 23	P01
Details	Eng	Date	Rev

Revisions

Consulting Engineers  
Faraday House, Terra Nova Way  
Purth Marina, Cardiff CF64 1SA  
Tel: (030) 3035 2480  
Fax: (030) 3035 2461  
www.mccann.com  
office@mccann.com

Job Title  
Unit A Fountain Court  
St Mellons

Drawing Title  
Electrical Services  
Level 01  
Lighting Strategy  
Option 1

Scale	Date	Author	Checked	Engineer	Drawn
1:50	Nov 23	CM	CM	RS	RS
7299				D2	P02
7299	MCP	V1	01	DR	E 1001